

上越工業用水道水質表

2 0 2 6 年 5 月

項目 日	原 水																	記 事
	濁 度			p H			水 温 ℃			導電率 μ S/cm			酸消 費量 mg/L	塩化物 イオン mg/L	全硬度 mg/L	鉄 mg/L	蒸発 残留物 mg/L	
	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低						
1	31	171	13	7.40	7.70	7.22	12.7	13.7	11.8	110	124	92	29	15	35	0.20	234	
2	91	331	35	7.29	7.36	7.19	12.9	15.2	10.7	86	97	80	20	10				
3	31	46	21	7.33	7.47	7.23	13.2	15.0	11.1	102	106	99	28	16				
4	41	61	24	7.33	7.43	7.24	13.7	14.3	12.5	100	110	88	22	15				
5	42	58	33	7.35	7.53	7.23	12.9	15.4	10.1	104	109	99	23	13				
6	36	48	25	7.33	7.51	7.18	13.5	15.8	10.9	114	117	109	24	11				
7	35	44	23	7.27	7.44	7.15	15.7	18.7	12.6	122	133	115	25	16				
8	33	56	21	7.25	7.43	7.09	15.3	16.6	14.1	122	130	114	28	13		0.20		
9	39	51	29	7.34	7.58	7.15	14.3	16.8	11.8	122	126	118	25	14				
10	35	47	26	7.28	7.49	7.11	14.7	17.5	11.9	129	137	125	30	19				
11	34	45	25	7.28	7.57	7.10	15.7	18.4	13.0	138	143	133	27	15				
12	30	41	21	7.28	7.66	7.01	17.1	19.9	14.4	141	149	136	27	14				
13	28	38	19	7.35	7.67	7.13	17.8	20.2	15.4	132	149	121	28	13				
14	25	34	17	7.35	7.71	7.13	17.0	19.0	14.6	127	136	121	27	14				
15	28	41	17	7.39	7.94	7.09	17.2	19.4	15.0	132	134	129	33	20	42	0.20	248	
16	26	40	19	7.42	7.98	7.08	17.5	20.1	15.0	134	137	129	31	17				
17	23	31	17	7.44	8.10	7.07	18.1	20.7	15.6	135	138	131	32	18				
18	26	37	17	7.38	7.98	7.07	18.7	21.5	15.9	137	146	129	28	15				
19	27	39	19	7.35	7.97	6.98	19.2	21.8	16.7	137	147	132	32	19				
20	25	33	17	7.23	7.64	7.02	18.9	20.5	17.1	140	145	133	27	15				
21	49	150	17	7.06	7.19	6.92	17.7	18.7	17.1	132	195	108	28	14				
22	53	76	37	7.11	7.21	7.03	17.4	18.6	16.5	103	113	92	31	15		0.20		
23	28	39	19	7.19	7.32	7.08	18.1	21.0	15.7	119	124	114	29	13				
24	29	36	22	7.16	7.27	7.06	17.6	19.0	16.2	131	139	124	31	16				
25	25	36	18	7.14	7.30	7.03	19.3	22.3	16.4	143	156	134	32	16				
26	22	32	16	7.13	7.29	7.03	20.5	22.3	18.4	146	155	140	30	17				
27	22	28	16	7.12	7.31	6.98	21.4	23.2	19.3	153	160	149	32	16				
28	20	27	14	7.10	7.30	6.97	20.9	21.9	19.9	155	162	148	36	17				
29	22	29	15	7.13	7.26	7.02	19.1	20.4	17.8	134	157	126	29	15	35	0.20	123	
30	16	24	11	7.19	7.34	7.06	19.3	22.5	16.1	143	159	137	32	15				
31	16	23	12	7.18	7.40	7.00	20.7	23.4	18.3	166	174	158	38	21				
最高	91	331	37	7.44	8.10	7.24	21.4	23.4	19.9	166	195	158	38	21	42	0.20	248	
最低	16	23	11	7.06	7.19	6.92	12.7	13.7	10.1	86	97	80	20	10	35	0.20	123	
平均	32	58	20	7.26	7.53	7.09	17.0	19.2	14.9	129	139	121	29	15	37	0.20	202	

上越工業用水道水質表

2026年5月

項目 日	処 理 水																	記 事	
	濁 度			p H			水 温			導電率			酸消 費量 mg/L	塩化物 イオン mg/L	全硬度 mg/L	鉄 mg/L	蒸発 残留物 mg/L		
	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低							
1	0.9	1.3	0.7	7.03	7.14	6.91	12.7	13.6	12.1	118	126	104	28	18	30	0.00	112		
2	1.1	1.5	0.7	6.83	6.90	6.72	13.0	14.8	11.3	93	103	89	18	12					
3	1.1	1.7	0.8	6.95	7.04	6.86	13.3	14.7	11.6	106	111	99	23	17					
4	1.0	1.4	0.7	6.91	7.02	6.79	13.9	14.2	13.3	107	114	98	20	18					
5	1.1	1.8	0.7	6.88	6.97	6.79	12.9	14.9	10.9	108	113	102	22	10					
6	1.2	1.6	0.8	6.91	7.00	6.82	13.5	15.5	11.6	119	123	112	22	15					
7	1.1	1.8	0.8	6.87	6.95	6.77	15.5	18.2	13.2	126	135	120	24	17					
8	1.0	1.3	0.8	6.90	6.99	6.83	15.7	17.6	14.9	128	133	123	25	15		0.00			
9	1.1	1.5	0.9	6.89	6.98	6.82	14.3	16.4	12.3	128	132	122	23	18					
10	1.4	2.0	1.1	6.89	6.93	6.85	14.8	16.9	12.6	134	140	131	28	21					
11	1.3	1.8	0.8	6.87	6.91	6.83	15.7	18.0	13.6	144	149	139	30	18					
12	1.1	1.8	0.8	6.82	6.86	6.79	17.1	19.5	14.9	147	154	143	25	18					
13	1.1	1.7	0.8	6.88	6.96	6.79	17.9	19.8	16.1	140	154	129	27	16					
14	1.1	1.7	0.8	6.94	7.06	6.81	17.2	18.7	15.3	132	139	128	27	16					
15	1.3	1.9	0.8	6.96	7.07	6.85	17.3	19.0	15.5	137	139	134	31	19	32	0.00	142		
16	1.2	2.0	0.8	6.94	7.03	6.82	17.6	19.6	15.6	139	143	135	29	17					
17	1.5	2.2	1.2	6.98	7.10	6.88	18.2	20.2	16.2	140	144	136	26	20					
18	1.3	2.0	0.8	6.92	7.02	6.84	18.7	21.1	16.5	142	151	136	27	16					
19	1.1	1.5	0.8	6.89	6.98	6.78	19.3	21.4	17.3	144	150	139	29	21					
20	1.0	1.5	0.8	6.87	6.93	6.77	19.1	20.3	17.6	145	149	139	26	17					
21	1.0	1.5	0.7	6.87	6.97	6.77	18.0	19.3	17.4	138	150	122	26	17					
22	1.1	1.6	0.6	6.88	6.94	6.82	17.4	18.4	16.6	109	121	101	22	20		0.00			
23	1.1	1.8	0.7	6.97	7.01	6.92	18.0	20.3	16.2	123	128	117	25	15					
24	1.2	1.5	0.8	6.99	7.06	6.94	17.8	19.2	16.6	135	142	128	30	16					
25	1.4	2.2	1.0	6.98	7.01	6.94	19.1	21.8	16.9	145	156	137	31	18					
26	1.1	1.9	0.7	6.95	7.00	6.90	20.6	22.0	19.0	152	160	148	30	21					
27	1.2	2.1	0.8	6.94	7.01	6.87	21.4	22.9	19.9	158	161	155	30	18					
28	1.1	1.4	0.7	6.92	6.99	6.85	21.1	22.1	20.3	161	165	157	34	19					
29	1.0	1.5	0.7	6.94	6.98	6.90	19.3	20.6	18.3	143	166	132	26	17	34	0.00	100		
30	1.2	2.2	0.8	6.98	7.03	6.92	19.2	22.0	16.8	146	158	141	31	18					
31	1.2	2.0	0.7	6.95	7.00	6.91	20.7	22.9	18.9	171	179	161	33	27					
最高	1.5	2.2	1.2	7.03	7.14	6.94	21.4	22.9	20.3	171	179	161	34	27	34	0.00	142		
最低	0.9	1.3	0.6	6.82	6.86	6.72	12.7	13.6	10.9	93	103	89	18	10	30	0.00	100		
平均	1.1	1.7	0.8	6.92	6.99	6.84	17.1	18.9	15.5	134	142	128	27	18	32	0.00	118		