

上越工業用水道水質表

2026年6月

項目 日	原 水																	記 事
	濁 度			p H			水 温			導電率			酸消 費量 mg/L	塩化物 イオン mg/L	全硬度 mg/L	鉄 mg/L	蒸発 残留物 mg/L	
	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低						
1	15	25	10	7.20	7.43	7.03	21.3	24.0	18.8	173	179	166	42	21	0.20			
2	17	26	13	7.13	7.27	7.02	20.4	21.3	19.5	173	178	168	39	20				
3	60	131	17	7.12	7.21	7.03	18.8	19.3	18.1	134	168	110	30	15				
4	25	46	15	7.22	7.41	7.08	20.3	23.6	17.4	126	140	113	31	13				
5	20	27	13	7.32	7.46	7.21	21.5	24.3	18.6	153	166	140	33	16				
6	17	26	13	7.31	7.47	7.17	21.5	22.5	20.6	169	174	164	40	22				
7	14	17	11	7.33	7.52	7.18	21.4	23.0	19.9	172	177	168	38	22				
8	14	19	12	7.29	7.42	7.20	19.9	20.8	19.1	173	188	162	42	18				
9	22	34	18	7.30	7.38	7.21	18.1	19.0	17.6	146	162	135	40	20				
10	15	23	9	7.33	7.48	7.21	19.4	23.0	16.9	148	160	139	36	15				
11	14	20	10	7.38	7.59	7.21	20.4	23.1	17.6	163	168	160	39	19	50	0.20	173	
12	17	24	13	7.35	7.53	7.24	20.7	22.9	18.6	164	175	156	42	20				
13	13	21	10	7.42	7.65	7.25	21.5	24.4	18.7	162	166	157	38	18				
14	13	33	8	7.41	7.76	7.22	21.9	24.0	20.0	166	178	127	41	19				
15	21	33	14	7.34	7.53	7.20	22.0	23.8	20.1	156	161	150	38	21				
16	13	19	10	7.40	7.68	7.21	22.2	24.6	19.7	167	173	163	40	22				
17	11	15	8	7.40	7.73	7.17	23.4	26.0	20.9	176	183	168	44	22				
18	10	12	8	7.38	7.72	7.17	23.9	26.2	21.8	182	189	175	45	19				
19	10	12	8	7.44	7.87	7.17	23.8	26.4	21.5	183	193	176	42	20				
20	18	101	8	7.32	7.62	6.99	22.7	23.8	20.9	180	189	145	46	23				
21	51	115	24	7.31	7.35	7.25	20.4	21.2	19.5	137	146	121	41	19	44	0.20	142	
22	15	23	11	7.37	7.48	7.28	20.0	21.0	19.1	147	155	140	41	15				
23	19	23	16	7.38	7.48	7.29	20.6	22.7	18.9	149	157	144	38	19				
24	13	18	11	7.40	7.54	7.31	21.8	24.7	18.8	163	168	158	40	17				
25	13	23	11	7.40	7.57	7.26	21.7	22.9	20.6	174	184	167	45	19				
26	20	27	13	7.40	7.48	7.32	20.3	21.2	19.5	158	180	144	42	19				
27	16	19	13	7.42	7.51	7.35	20.2	21.6	19.4	150	156	140	41	19				
28	12	15	10	7.43	7.55	7.33	21.3	24.0	18.8	161	165	157	39	20				
29	11	12	9	7.42	7.59	7.29	23.2	26.0	20.6	169	177	165	43	19				
30	12	14	10	7.42	7.59	7.27	23.5	25.5	21.8	173	179	164	46	22				
31																		
最高	60	131	24	7.44	7.87	7.35	23.9	26.4	21.8	183	193	176	46	23	50	0.20	173	
最低	10	12	8	7.12	7.21	6.99	18.1	19.0	16.9	126	140	110	30	13	44	0.20	142	
平均	18	32	12	7.34	7.53	7.20	21.3	23.2	19.4	162	171	151	40	19	47	0.20	158	

上越工業用水道水質表

2026年6月

項目 日	処 理 水																	記 事	
	濁 度			p H			水 温			導電率			酸消 費量 mg/L	塩化物 イオン mg/L	全硬度 mg/L	鉄 mg/L	蒸発 残留物 mg/L		
	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低							
1	1.4	2.1	1.1	6.98	7.02	6.93	21.4	23.5	19.4	178	185	172	38	23					
2	1.4	1.6	1.1	6.96	7.02	6.88	20.7	22.3	20.0	181	184	176	35	21					
3	1.0	1.4	0.6	6.90	6.99	6.85	19.0	19.8	18.6	148	177	119	26	20					
4	1.1	2.2	0.8	6.92	6.98	6.87	20.0	23.1	17.7	129	142	119	26	16					
5	1.2	2.2	0.7	6.96	7.02	6.90	21.5	23.9	19.2	156	164	144	33	20		0.00			
6	1.3	1.8	0.8	6.98	7.05	6.92	21.7	22.8	20.9	174	178	168	38	23					
7	1.2	1.4	0.9	6.98	7.02	6.93	21.5	22.7	20.4	177	182	173	35	24					
8	1.1	1.5	0.9	6.99	7.04	6.93	20.2	21.5	19.5	179	188	174	40	22					
9	1.3	1.8	0.9	6.97	7.03	6.91	18.2	19.4	17.7	155	177	142	36	22					
10	1.2	2.3	0.9	6.96	7.02	6.93	19.1	22.1	17.1	152	159	143	34	17					
11	1.4	2.0	0.8	6.99	7.05	6.93	20.4	22.7	18.2	169	172	162	36	19					
12	1.2	1.8	0.8	6.97	7.01	6.91	20.8	22.5	19.2	171	179	164	38	22	44	0.00	142		
13	1.3	1.7	1.1	7.01	7.06	6.96	21.4	23.9	19.3	167	171	163	36	21					
14	1.2	1.6	0.9	7.01	7.12	6.93	22.0	23.5	20.5	174	183	155	40	21					
15	1.6	2.2	1.1	6.92	7.00	6.85	22.0	23.5	20.6	161	166	155	34	24					
16	1.3	1.6	1.0	6.97	7.06	6.89	22.3	24.2	20.4	174	179	168	39	23					
17	1.4	1.7	1.1	6.99	7.10	6.88	23.4	25.5	21.4	182	187	174	40	25					
18	1.3	1.8	0.9	6.99	7.10	6.87	24.1	25.8	22.4	188	195	182	39	21					
19	1.5	1.7	1.3	7.02	7.13	6.94	23.9	26.0	21.9	190	199	184	40	24		0.00			
20	1.1	1.4	0.8	6.97	7.08	6.83	23.1	24.9	22.1	189	194	173	43	24					
21	1.1	1.7	0.7	6.88	6.94	6.85	20.6	21.8	19.8	145	166	134	37	23					
22	1.0	1.3	0.7	7.00	7.05	6.92	20.1	20.8	19.4	151	158	144	39	18					
23	1.0	1.9	0.6	6.94	7.00	6.91	20.6	22.4	19.2	156	161	151	36	22					
24	1.0	1.3	0.8	7.00	7.04	6.95	21.7	24.2	19.3	168	174	160	40	21					
25	1.0	1.2	0.8	7.01	7.08	6.95	22.0	23.1	21.0	179	187	173	43	20					
26	1.0	1.3	0.7	6.98	7.02	6.94	20.6	21.5	20.2	167	187	155	38	23	38	0.00	133		
27	1.1	1.3	0.9	7.00	7.02	6.97	20.2	21.3	19.6	156	161	149	39	23					
28	1.1	1.5	0.8	7.03	7.07	6.99	21.2	23.6	19.2	165	170	160	38	22					
29	1.1	1.5	0.8	7.05	7.10	7.00	23.2	25.6	21.2	173	178	169	42	21					
30	1.1	1.5	0.8	7.02	7.11	6.95	23.8	25.2	22.3	180	184	173	45	26					
31																			
最高	1.6	2.3	1.3	7.05	7.13	7.00	24.1	26.0	22.4	190	199	184	45	26	44	0.00	142		
最低	1.0	1.2	0.6	6.88	6.94	6.83	18.2	19.4	17.1	129	142	119	26	16	38	0.00	133		
平均	1.2	1.7	0.9	6.98	7.04	6.92	21.4	23.1	19.9	168	176	159	37	22	41	0.00	138		