

上越工業用水道水質表

2026年7月

項目 日	原 水																	記 事
	濁 度			p H			水 温			導電率			酸消 費量 mg/L	塩化物 イオン mg/L	全硬度 mg/L	鉄 mg/L	蒸発 残留物 mg/L	
	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低						
1	11	13	10	7.39	7.60	7.25	22.6	24.1	21.2	173	179	167	45	19				0.20
2	24	48	11	7.36	7.45	7.26	20.9	21.8	20.1	157	185	139	37	18				
3	16	22	12	7.40	7.55	7.32	21.3	23.9	19.3	151	173	143	41	17				
4	12	16	10	7.39	7.56	7.26	21.7	24.0	19.5	163	166	158	41	19				
5	10	12	8	7.39	7.59	7.23	22.3	23.8	20.7	166	168	162	42	18				
6	12	14	9	7.35	7.53	7.23	22.0	22.8	21.5	166	174	159	42	21				
7	10	12	8	7.39	7.64	7.23	22.6	24.4	20.8	168	174	162	42	19				
8	9	12	7	7.41	7.72	7.19	24.5	27.5	21.7	178	187	173	43	21				
9	9	13	8	7.40	7.76	7.13	26.4	29.3	23.6	189	197	182	46	26	64	0.20	119	
10	9	10	8	7.43	7.80	7.14	27.2	29.7	24.7	195	201	190	52	25				
11	9	11	7	7.35	7.68	7.12	26.2	27.5	24.8	196	204	189	48	23				0.20
12	9	12	7	7.34	7.62	7.12	24.7	25.4	24.0	189	194	182	45	22				
13	8	9	7	7.41	7.72	7.20	25.2	27.0	23.6	186	191	183	44	22				
14	8	10	7	7.37	7.70	7.11	26.7	29.1	24.3	191	197	185	47	20				
15	8	9	7	7.32	7.68	7.07	27.7	29.8	25.0	199	209	187	47	23				
16	10	24	8	7.28	7.72	7.00	27.5	29.3	26.0	191	200	183	49	26				
17	8	9	7	7.33	7.71	7.07	26.8	28.2	25.6	185	200	177	42	20		0.20		
18	20	88	7	7.24	7.67	7.05	26.7	28.7	25.5	182	198	134	48	26				
19	42	119	13	7.20	7.41	7.10	26.5	29.3	24.1	153	178	135	33	15				
20	10	13	8	7.33	7.81	7.03	28.7	31.5	26.1	179	187	174	42	19				
21	9	11	8	7.40	8.00	7.03	29.2	31.5	26.9	191	199	184	47	22				0.20
22	9	10	8	7.58	8.51	7.02	29.1	31.6	26.8	204	214	191	47	29				
23	9	11	8	7.71	8.56	7.04	29.0	30.9	27.0	206	216	198	50	25				
24	9	10	8	7.71	8.62	7.06	28.3	29.9	26.5	204	219	195	52	28	60	0.20	178	
25	10	12	8	7.23	7.42	7.06	26.7	27.6	25.9	189	209	173	45	23				
26	53	125	8	7.05	7.14	6.83	24.3	25.7	23.3	153	192	122	35	20				
27	121	250	27	7.02	7.08	6.95	24.2	26.2	22.8	118	138	94	26	12				
28	45	104	20	7.13	7.22	7.05	23.3	24.2	22.6	140	152	119	36	17				
29	29	47	16	7.25	7.32	7.20	23.2	24.5	22.1	147	157	138	37	14				
30	16	19	13	7.24	7.33	7.17	23.7	25.0	22.5	167	177	159	44	17				
31	13	16	10	7.30	7.48	7.19	25.4	27.7	23.3	177	181	169	42	17		0.20		
最高	121	250	27	7.71	8.62	7.32	29.2	31.6	27.0	206	219	198	52	29	64	0.20	178	
最低	8	9	7	7.02	7.08	6.83	20.9	21.8	19.3	118	138	94	26	12	60	0.20	119	
平均	19	35	10	7.35	7.66	7.12	25.3	27.2	23.6	176	188	165	43	21	62	0.20	149	

上越工業用水道水質表

2 0 2 6 年 7 月

項目 日	処 理 水																	記 事	
	濁 度			p H			水 温			導電率			酸消 費量 mg/L	塩化物 イオン mg/L	全硬度 mg/L	鉄 mg/L	蒸発 残留物 mg/L		
	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低							
1	1.0	1.5	0.7	7.02	7.11	6.94	22.8	23.9	21.7	179	185	174	41	22					
2	0.9	1.1	0.7	6.97	7.01	6.87	21.3	22.6	20.6	165	188	147	36	20					
3	1.1	1.7	0.7	7.02	7.06	6.97	21.2	23.4	19.5	155	167	149	37	19		0.00			
4	0.8	1.3	0.6	7.02	7.07	6.98	21.8	23.6	20.0	169	172	163	39	21					
5	1.0	1.2	0.7	7.08	7.15	7.01	22.3	23.6	21.0	170	172	163	40	21					
6	1.0	1.3	0.7	7.07	7.12	7.00	22.2	22.8	21.8	172	177	165	40	22					
7	1.1	1.4	0.8	7.07	7.12	7.00	22.5	24.2	21.0	172	177	165	40	22					
8	1.1	1.4	0.8	7.06	7.14	6.99	24.4	27.1	22.0	182	191	178	40	27					
9	1.0	1.5	0.7	7.00	7.07	6.93	26.4	28.9	24.1	195	200	190	46	32	54	0.00	77		
10	1.0	1.6	0.8	7.01	7.08	6.94	27.3	29.4	25.2	201	205	194	47	31					
11	1.0	1.3	0.8	7.01	7.10	6.91	26.5	28.2	25.2	202	209	197	45	24					
12	0.9	1.1	0.6	7.02	7.15	6.89	24.9	26.3	24.3	196	202	188	41	26					
13	1.1	1.5	0.7	7.09	7.22	6.97	25.1	26.8	23.8	190	194	187	42	23					
14	1.1	2.6	0.7	7.05	7.15	6.94	26.7	28.7	24.9	198	202	194	43	26					
15	1.1	2.0	0.7	7.00	7.12	6.89	27.7	29.6	25.7	204	213	195	47	29					
16	1.0	1.5	0.8	6.96	7.06	6.82	27.7	28.9	26.4	199	206	191	49	29					
17	1.0	1.2	0.8	6.99	7.10	6.87	26.9	27.9	25.9	192	204	184	42	26		0.00			
18	1.0	2.0	0.7	6.96	7.08	6.85	26.9	28.4	25.7	192	202	161	46	32					
19	1.4	2.1	1.0	6.80	6.85	6.74	26.4	28.9	24.4	157	174	147	30	20					
20	1.0	1.2	0.7	6.94	7.10	6.81	28.7	31.0	26.7	184	191	179	41	22					
21	1.0	1.5	0.6	7.01	7.21	6.85	29.4	31.2	27.5	196	203	189	42	26					
22	1.1	1.9	0.8	7.07	7.33	6.85	29.3	31.1	27.3	209	219	198	46	30					
23	1.0	1.5	0.6	7.11	7.35	6.92	29.1	30.6	27.4	213	223	206	48	29					
24	0.8	1.3	0.6	7.11	7.32	6.92	28.5	29.7	27.1	212	223	204	46	29	54	0.00	168		
25	1.0	1.5	0.7	7.02	7.11	6.94	27.0	28.3	26.2	197	213	179	43	25					
26	0.8	1.0	0.5	6.84	6.95	6.70	24.6	26.0	23.6	164	195	135	34	27					
27	1.3	2.4	0.5	6.72	6.81	6.67	24.2	25.9	23.0	124	136	113	22	16					
28	1.1	2.0	0.7	6.90	7.00	6.80	23.5	24.9	22.9	144	155	131	33	19					
29	1.0	1.7	0.7	6.93	6.97	6.82	23.2	24.3	22.2	151	160	145	34	16					
30	0.8	1.3	0.6	6.97	7.00	6.94	23.7	24.8	22.7	170	180	161	42	19					
31	1.0	1.6	0.6	7.01	7.07	6.93	25.2	27.5	23.6	182	185	179	41	21		0.00			
最高	1.4	2.6	1.0	7.11	7.35	7.01	29.4	31.2	27.5	213	223	206	49	32	54	0.00	168		
最低	0.8	1.0	0.5	6.72	6.81	6.67	21.2	22.6	19.5	124	136	113	22	16	54	0.00	77		
平均	1.0	1.6	0.7	6.99	7.10	6.89	25.4	27.0	24.0	182	191	173	41	24	54	0.00	123		