

上越工業用水道水質表

2026年9月

項目 日	原 水																	記 事
	濁 度			p H			水 温			導電率			酸消 費量 mg/L	塩化物 イオン mg/L	全硬度 mg/L	鉄 mg/L	蒸発 残留物 mg/L	
	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低						
1	23	34	15	7.28	7.32	7.23	22.9	24.7	21.0	137	146	127	36	16	38	0.20	175	
2	20	29	14	7.31	7.36	7.23	23.4	24.7	21.9	148	155	142	41	18				
3	41	89	16	7.25	7.31	7.14	22.0	23.2	20.6	143	157	119	32	18				
4	38	67	20	7.27	7.32	7.17	20.6	21.0	19.8	130	144	110	31	12				
5	18	26	14	7.34	7.41	7.29	20.6	22.4	19.0	149	154	145	34	14				
6	14	16	13	7.36	7.44	7.29	20.0	20.8	18.9	157	166	152	42	15				
7	12	14	11	7.39	7.54	7.31	20.6	21.7	19.5	161	167	149	40	19				
8	14	24	10	7.37	7.48	7.31	20.5	21.0	19.8	155	161	150	43	18				
9	113	225	24	7.18	7.33	7.06	20.9	21.9	19.4	113	154	94	23	10				
10	48	116	22	7.29	7.34	7.19	19.0	19.7	18.3	124	132	108	32	12				
11	16	20	13	7.32	7.39	7.25	18.8	20.0	17.9	134	139	129	31	13	55	0.20	124	
12	11	13	10	7.33	7.42	7.26	19.6	21.1	18.6	142	150	136	36	17				
13	8	11	7	7.34	7.46	7.26	20.4	21.9	18.9	153	157	150	39	17				
14	8	9	6	7.35	7.47	7.27	21.1	21.8	20.2	160	166	157	46	18				
15	10	15	7	7.38	7.51	7.32	19.8	20.6	19.5	159	165	154	39	16				
16	36	76	9	7.31	7.38	7.22	19.5	19.9	18.9	137	161	112	45	15				
17	21	48	12	7.36	7.47	7.28	19.4	20.6	18.3	144	155	126	39	16				
18	9	11	7	7.40	7.54	7.31	20.0	21.5	18.2	156	162	153	39	17				
19	7	9	6	7.42	7.64	7.30	20.5	21.9	18.9	160	163	155	43	17				
20	17	34	6	7.32	7.47	7.23	20.8	21.3	20.3	143	163	125	34	16				
21	10	37	7	7.36	7.55	7.27	20.1	21.0	19.3	145	150	129	39	18	0.20			
22	249	727	53	7.30	7.37	7.21	20.3	21.1	19.1	122	133	105	29	13				
23	32	51	22	7.40	7.54	7.31	19.3	20.7	17.7	138	142	134	33	11				
24	16	25	12	7.40	7.58	7.28	19.7	20.8	18.7	150	154	145	40	17				
25	10	13	8	7.46	7.71	7.31	19.4	20.5	18.2	155	156	154	38	14				
26	11	14	9	7.45	7.63	7.33	18.3	19.4	17.6	154	160	150	42	15				
27	8	11	7	7.54	7.88	7.37	18.4	19.7	17.1	159	165	154	44	19				
28	21	41	7	7.36	7.44	7.28	19.2	20.3	18.3	150	168	119	38	13				
29	117	382	28	7.19	7.29	6.95	18.9	20.0	17.7	119	140	83	30	11				
30	17	28	12	7.38	7.52	7.29	18.3	20.0	16.8	147	155	139	36	18				
31																		
最高	249	727	53	7.54	7.88	7.37	23.4	24.7	21.9	161	168	157	46	19	55	0.20	175	
最低	7	9	6	7.18	7.29	6.95	18.3	19.4	16.8	113	132	83	23	10	38	0.20	124	
平均	33	74	14	7.35	7.47	7.25	20.1	21.2	18.9	145	155	134	37	15	47	0.20	150	

上越工業用水道水質表

2 0 2 6 年 9 月

項目 日	処 理 水																	記 事	
	濁 度			p H			水 温			導電率			酸消 費量 mg/L	塩化物 イオン mg/L	全硬度 mg/L	鉄 mg/L	蒸発 残留物 mg/L		
	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低	平 均	最 高	最 低							
1	1.0	1.8	0.7	6.88	6.96	6.83	23.0	24.4	21.5	141	148	132	32	17	33	0.00	89		
2	1.0	1.3	0.7	6.95	7.02	6.88	23.6	24.7	22.4	152	157	145	34	21					
3	1.3	1.9	0.6	6.94	7.05	6.66	22.4	23.9	21.2	148	158	131	30	21					
4	1.1	2.0	0.7	6.92	7.02	6.85	20.8	21.3	20.3	137	150	123	27	15					
5	0.8	1.3	0.6	7.03	7.09	6.98	20.7	22.1	19.5	153	157	148	32	15					
6	0.9	1.2	0.7	7.11	7.14	7.08	20.2	21.1	19.4	160	168	157	40	17					
7	1.0	1.4	0.7	7.14	7.19	7.11	20.8	21.8	19.9	166	170	157	39	19					
8	0.9	1.9	0.7	7.12	7.17	7.10	20.7	21.3	20.3	161	166	156	40	20					
9	1.2	2.4	0.6	6.82	7.10	6.61	21.1	21.8	20.1	126	157	107	23	17					
10	1.0	1.7	0.8	6.87	7.04	6.67	19.3	19.9	18.8	127	135	111	27	17					
11	1.1	1.5	0.6	7.05	7.10	7.00	19.0	20.0	18.2	137	142	134	29	15	52	0.00	114		
12	0.9	1.6	0.5	7.08	7.13	7.03	19.8	20.8	19.0	145	151	140	34	18					
13	0.8	1.5	0.5	7.11	7.15	7.08	20.5	21.8	19.3	156	161	152	39	17					
14	0.8	1.3	0.6	7.11	7.14	7.08	21.3	21.7	20.8	163	168	160	43	19					
15	0.8	1.3	0.6	7.11	7.16	7.06	20.1	21.1	19.7	163	168	158	39	16					
16	1.2	1.9	0.6	6.97	7.10	6.77	19.6	19.9	19.3	147	166	125	39	18					
17	1.0	1.7	0.6	6.94	7.03	6.80	19.4	20.4	18.5	146	157	128	34	17					
18	0.9	1.3	0.6	7.10	7.12	7.05	20.1	21.4	18.6	160	163	157	36	17					
19	0.9	1.1	0.7	7.14	7.21	7.10	20.7	21.7	19.5	163	165	159	41	17					
20	1.1	1.6	0.7	7.04	7.14	6.97	21.0	21.4	20.7	149	166	135	31	17					
21	0.9	1.3	0.7	7.11	7.17	7.03	20.2	20.7	19.6	149	153	145	40	17	0.00	0.00			
22	1.2	2.5	0.6	6.79	7.05	6.60	20.6	21.0	19.9	133	142	124	27	17					
23	1.1	1.6	0.7	7.01	7.05	6.95	19.4	20.5	18.2	142	146	137	31	16					
24	1.0	1.5	0.7	7.11	7.15	7.01	19.9	20.6	19.0	152	157	145	39	17					
25	0.8	1.2	0.6	7.15	7.23	7.07	19.6	20.4	18.7	159	160	157	38	15					
26	0.8	1.0	0.7	7.18	7.24	7.13	18.6	19.6	17.8	158	162	155	40	18					
27	1.0	1.3	0.8	7.22	7.32	7.13	18.4	19.6	17.4	162	166	156	40	22					
28	1.2	2.2	0.9	7.11	7.21	6.91	19.2	19.9	18.6	158	170	140	37	16					
29	1.1	1.9	0.6	6.79	6.91	6.61	19.2	19.9	18.1	128	143	108	22	18					
30	0.9	1.7	0.6	7.04	7.10	6.95	18.4	19.7	17.1	150	157	143	34	20					
31																			
最高	1.3	2.5	0.9	7.22	7.32	7.13	23.6	24.7	22.4	166	170	160	43	22	52	0.00	114		
最低	0.8	1.0	0.5	6.79	6.91	6.60	18.4	19.6	17.1	126	135	107	22	15	33	0.00	89		
平均	1.0	1.6	0.7	7.03	7.12	6.94	20.3	21.1	19.4	150	158	141	35	18	43	0.00	102		